

## UNT AGL BRAIDING POWER FLEX – B

### ÖRGÜ EKLANLI PRİMER PİST AYDINLATMA KABLOSU – TİP B

PRIMARY AIRPORT LIGHTING CABLE WITH BRAIDING SCREEN – TYPE B

### ICEA S-93-639 / NEMA WC74

FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)

#### KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TB ) veya Kalaylı (Tip BB ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* YARI İLETKEN TABAKA : Ekstruze yarı iletken tabaka - ICEA S-93-639 / NEMA WC74' e göre
- \* İZOLE : EPR Kauçuk - ICEA S-93-639 / NEMA WC74' e göre
- \* YARI İLETKEN TABAKA : Yarı iletken bant - ICEA S-93-639 / NEMA WC74' e göre
- \* EKLAN : Kalaylı bakır tellerden Minimum %80 örtme oranı ile örgü bakır ekran.
- \* DIŞ KILIF : PCP veya eşdeğeri malzeme - ICEA S-93-639 / NEMA WC74' e göre

#### CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TB ) or plain copper wires (Type BB ) according to IEC C 60228 CL 2
- \* SEMICONDUCTIVE LAYER : Extruded Semiconductive material according to ICEA S-93-639 / NEMA WC74
- \* INSULATION : EPR Rubber according to ICEA S-93-639 / NEMA WC74
- \* SEMICONDUCTIVE LAYER : Semiconductive tape according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Tinned Copper wire braiding with minimum 80% coverage ratio
- \* OUTER JACKET : PCP or equivalent according to ICEA S-93-639 / NEMA WC74



#### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARTI / STANDARD OF TEST : ICEA S-93-639 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
All sizes are available in AWG and Metric

## UNT AGL BRASS POWER – C

**PİRİNÇ BANT EKSPANLI PRİMER PİST AYDINLATMA KABLOSU – TİP C**  
*PRIMARY AIRPORT LIGHTING CABLE WITH BRASS TAPE SCREEN – TYPE C*

**ICEA S-93-639 / NEMA WC74**

*FAA – L 824 – TYPE C ( AC - 150/5375-7E SPECIFICATION FOR L-824)*

### KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TBC ) veya Kalaylı (Tip BBC ) Bakır İletken - IEC C60228 CL 2' ye göre
- \* YARI İLETKEN TABAKA : Ekstruze yarı iletken tabaka - ICEA S-93-639 / NEMA WC74' e göre
- \* İZOLE : XLPE - ICEA S-93-639 / NEMA WC74' e göre
- \* YARI İLETKEN TABAKA : Yarı iletken bant - ICEA S-93-639 / NEMA WC74' e göre
- \* EKSPAN : Minimum %20 bindirmeli ve %100 kapamalı olarak helisel uygulanmış pirinç bant
- \* DIŞ KILIF : Polyethylene (PE), PVC veya Halojeniz (HF) malzeme - ICEA S-93-639 / NEMA WC74' e göre

### CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TBC ) or plain copper wires (Type BBC ) according to IEC C 60228 CL 2
- \* SEMICONDUCTIVE LAYER : Extruded Semiconductive material according to ICEA S-93-639 / NEMA WC74
- \* INSULATION : XLPE according to ICEA S-93-639 / NEMA WC74
- \* SEMICONDUCTIVE LAYER : Semiconductive tape according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Minimum 20% overlap and 100% coverage ratio helically applied Brass Tape
- \* OUTER JACKET : PE, PVC, HF material according to ICEA S-93-639 / NEMA WC74



### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARTI / STANDARD OF TEST : ICEA S-93-639 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
*All sizes are available in AWG and Metric*

# UNT AGL COPPER POWER - C

**BAKIR BANT EKLANLI PRİMER PİST AYDINLATMA KABLOSU – TİP C**  
**PRIMARY AIRPORT LIGHTING CABLE WITH COPPER TAPE SCREEN – TYPE C**

**ICEA S-93-639 / NEMA WC74**

**FAA – L 824 – TYPE C ( AC - 150/5375-7E SPECIFICATION FOR L-824)**

## KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TCC ) veya Kalaylı (Tip BCC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* YARI İLETKEN TABAKA : Ekstruze yarı iletken tabaka - ICEA S-93-639 / NEMA WC74' e göre
- \* İZOLE : XLPE - ICEA S-93-639 / NEMA WC74' e göre
- \* YARI İLETKEN TABAKA : Yarı iletken bant - ICEA S-93-639 / NEMA WC74' e göre
- \* EKLAN : %20 bindirmeli ve %100 kapamalı olarak helisel uygulanmış Bakır Bant
- \* DIŞ KILIF : Polyethylene (PE), PVC or Halojensiz (HF) malzeme - ICEA S-93-639 / NEMA WC74' e göre

## CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TBC ) or plain copper wires (Type BBC ) according to IEC C 60228 CL 2
- \* SEMICONDUCTIVE LAYER : Extruded Semiconductive material according to ICEA S-93-639 / NEMA WC74
- \* INSULATION : XLPE according to ICEA S-93-639 / NEMA WC74
- \* SEMICONDUCTIVE LAYER : Semiconductive tape according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Minimum 20% overlap and 100% coverage ratio helically applied Copper Tape
- \* OUTER JACKET : PE, PVC, HF material according to ICEA S-93-639 / NEMA WC74



## ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : ICEA S-93-639 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
 All sizes are available in AWG and Metric

## UNT AGL COPPER SPECIAL FLEX - B

**BAKIR BANT EKLANLI ÖZEL ESNEK PRİMER PİST AYDINLATMA KABLOSU – TİP B**  
*SPECIAL FLEXIBLE PRIMARY AIRPORT LIGHTING CABLE WITH COPPER TAPE SCREEN – TYPE B*

**ICEA S-93-639 / NEMA WC74**

*FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)*

### KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TCC ) veya Kalaylı (Tip BCC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* İZOLE : EPR Kauçuk - ICEA S-93-639 / NEMA WC74' e göre
- \* EKLAN : Minimum %20 bindirmeli ve %100 kapamalı olarak helisel uygulanmış Bakır Bant
- \* DIŞ KILIF : PCP veya esdeğeri malzeme - ICEA S-93-639 / NEMA WC74' e göre

### CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TBC ) or plain copper wires (Type BBC ) according to IEC C 60228 CL 2
- \* INSULATION : EPR Rubber according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Minimum 20% overleap and 100% coverage ratio helically applied Copper Tape
- \* OUTER JACKET : PCP or equivalent material according to ICEA S-93-639 / NEMA WC74



### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARTI / STANDARD OF TEST : ICEA S-93-659 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
*All sizes are available in AWG and Metric*

## UNT AGL SECONDARY POWER – C

### SEKONDER PİST AYDINLATMA KABLOSU – TİP C SECONDARY AIRPORT LIGHTING CABLE – TYPE C

**FAA – L 824**  
( AC - 150/5375-7E SPECIFICATION FOR L-824 )

#### KABLO YAPISI

- \* İLETKEN : İnce çok telli Tavlı Bakır İletken (Tip TC ) veya İnce çok telli Kalaylı (Tip BC) Bakır İletken
- \* İZOLE : XLPE
- \* DIŞ KILIF : Polyethylene (PE), PVC veya Halojensiz (HF) malzeme

#### CABLE STRUCTURE

- \* CONDUCTOR : Fine Strand of annealed tinned copper wires (Type TC ) or fine plain copper wires (Type BC )
- \* INSULATION : XLPE
- \* OUTER JACKET : PE, PVC or HF material



#### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 600 V
- TEST GERİLİMİ / TEST VOLTAGE : 2 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 10 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : FAA – L 824 AC - 150/5375-7E

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
All sizes are available in AWG and Metric

## UNT AGL SECONDARY POWER FLEX – B

### SEKONDER PİST AYDINLATMA KABLOSU – TİP B

SECONDARY AIRPORT LIGHTING CABLE – TYPE B

### ICEA S-93-659 / NEMA WC71

FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)

#### KABLO YAPISI

- \* İLETKEN : İnce çok telli Tavlı Bakır İletken (Tip TB ) veya İnce çok telli Kalaylı (Tip BB) Bakır İletken
- \* İZOLE : EPR Kauçuk
- \* DIŞ KILIF : PCP veya eşdeğeri malzeme

#### CABLE STRUCTURE

- \* CONDUCTOR : Fine Strand of annealed tinned copper wires (Type TC ) or fine plain copper wires (Type BC )
- \* INSULATION : EPR Rubber
- \* OUTER JACKET : PCP or equivalent



#### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 600 V
- TEST GERİLİMİ / TEST VOLTAGE : 2 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 10 x Outer Diameter
- TEST STANDARTI / STANDARD OF TEST : FAA – L 824 AC - 150/5375-7E

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
All sizes are available in AWG and Metric

## UNT AGL UNSCREENED FLEX POWER-B

**EKRANSIZ ESNEK PRİMER PİST AYDINLATMA KABLOSU – TİP B**  
*UNSCREENED FLEXIBLE PRIMARY AIRPORT LIGHTING CABLE – TYPE B*

**ICEA S-93-659 / NEMA WC71**  
*FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)*

### KABLO YAPISI

- \* **İLETKEN** : Tavlı Bakır İletken (Tip TC ) veya Kalaylı (Tip BC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* **YARI İLETKEN TABAKA** : Ekstruze yarı iletken tabaka - ICEA S-93-659 / NEMA WC71' e göre
- \* **İZOLE** : EPR Kauçuk - ICEA S-93-659 / NEMA WC71' e göre
- \* **DIŞ KILIF** : PCP veya eşdeğeri malzeme - ICEA S-93-659 / NEMA WC71' e göre

### CABLE STRUCTURE

- \* **CONDUCTOR** : Strand of annealed tinned copper wires (Type TC ) or plain copper wires (Type BC ) according to IEC C 60228 CL 2
- \* **SEMICONDUCTIVE LAYER** : Extruded Semiconductive material according to ICEA S-93-659 / NEMA WC71
- \* **INSULATION** : EPR Rubber according to ICEA S-93-659 / NEMA WC71
- \* **OUTER JACKET** : PCP or equivalent according to ICEA S-93-659 / NEMA WC71



### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 6 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : ICEA S-93-659 / NEMA WC71

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
*All sizes are available in AWG and Metric*



# UNT AGL UNSCREENED POWER - C

**EKRANSIZ PRİMER PİST AYDINLATMA KABLOSU – TİP C**  
**UNSCREENED PRIMARY AIRPORT LIGHTING CABLE – TYPE C**

**ICEA S-93-659 / NEMA WC71**

**FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)**

## KABLO YAPISI

- \* **İLETKEN** : Tavlı Bakır İletken (Tip TC ) veya Kalaylı (Tip BC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* **YARI İLETKEN TABAKA** : Ekstruze yarı iletken tabaka - ICEA S-93-659 / NEMA WC71' e göre
- \* **İZOLE** : XLPE - ICEA S-93-659 / NEMA WC71' e göre
- \* **DIŞ KILIF** : Polyethylene (PE), PVC veya Halojensiz (HF) malzeme - ICEA S-93-659 / NEMA WC71' e göre

## CABLE STRUCTURE

- \* **CONDUCTOR** : Strand of annealed tinned copper wires (Type TC ) or plain copper wires (Type BC ) according to IEC C 60228 CL 2
- \* **SEMICONDUCTIVE LAYER** : Extruded Semiconductive material according to ICEA S-93-659 / NEMA WC71
- \* **INSULATION** : XLPE according to ICEA S-93-659 / NEMA WC71
- \* **OUTER JACKET** : PE, PVC or HF material according to ICEA S-93-659 / NEMA WC71



## ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 9 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : ICEA S-93-659 / NEMA WC71

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
All sizes are available in AWG and Metric



## UNT AGL COPPER POWER FLEX – B

**BAKIR BANT EKSPANLI ESNEK PRİMER PİST AYDINLATMA KABLOSU – TİP B**  
*FLEXIBLE PRIMARY AIRPORT LIGHTING CABLE WITH COPPER TAPE SCREEN – TYPE B*

**ICEA S-93-639 / NEMA WC74**

*FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)*

### KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TCC ) veya Kalaylı (Tip BCC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* YARI İLETKEN TABAKA : Ekstruze yarı iletken tabaka - ICEA S-93-639 / NEMA WC74' e göre
- \* İZOLE : EPR Kauçuk - ICEA S-93-639 / NEMA WC74' e göre
- \* YARI İLETKEN TABAKA : Yarı iletken bant - ICEA S-93-639 / NEMA WC74' e göre
- \* EKSPAN : Minimum %20 bindirmeli ve %100 kapamalı olarak helisel uygulanmış bakır bant
- \* DIŞ KILIF : PCP veya eşdeğeri malzeme - ICEA S-93-639 / NEMA WC74' e göre

### CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TBC ) or plain copper wires (Type BBC ) according to IEC C 60228 CL 2
- \* SEMICONDUCTIVE LAYER : Extruded Semiconductive material according to ICEA S-93-639 / NEMA WC74
- \* INSULATION : EPR Rubber according to ICEA S-93-639 / NEMA WC74
- \* SEMICONDUCTIVE LAYER : Semiconductive tape according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Minimum 20% overlap and 100% coverage ratio helically applied Copper Tape
- \* OUTER JACKET : PCP or equivalent material according to ICEA S-93-639 / NEMA WC74



### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARTI / STANDARD OF TEST : ICEA S-93-639 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
*All sizes are available in AWG and Metric*

# UNT AGL BRAIDING POWER – C

## ÖRGÜ EKSPANLI PRİMER PİST AYDINLATMA KABLOSU – TİP C

PRIMARY AIRPORT LIGHTING CABLE WITH BRAIDING SCREEN – TYPE C

### ICEA S-93-639 / NEMA WC74

FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)

#### KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TC ) veya Kalaylı (Tip BC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* YARI İLETKEN TABAKA : Ekstruze yarı iletken tabaka - ICEA S-93-639 / NEMA WC74' e göre
- \* İZOLE : XLPE - ICEA S-93-639 / NEMA WC74' e göre
- \* YARI İLETKEN TABAKA : Yarı iletken bant - ICEA S-93-639 / NEMA WC74' e göre
- \* EKSPAN : Kalaylı bakır tellerden Minimum %80 örtme oranı ile örgü bakır ekran.
- \* DIŞ KILIF : Polyethylene (PE) veya PVC, Halojeniz (HF) malzeme - ICEA S-93-639 / NEMA WC74' e göre

#### CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TC ) or plain copper wires (Type BC ) according to IEC C 60228 CL 2
- \* SEMICONDUCTIVE LAYER : Extruded Semiconductive material according to ICEA S-93-639 / NEMA WC74
- \* INSULATION : XLPE according to ICEA S-93-639 / NEMA WC74
- \* SEMICONDUCTIVE LAYER : Semiconductive tape according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Tinned Copper wire braiding with minimum 80% coverage ratio
- \* OUTER JACKET : PE, PVC or HF material according to ICEA S-93-639 / NEMA WC74



#### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : ICEA S-93-639 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
All sizes are available in AWG and Metric

## UNT AGL BRASS POWER FLEX – B

**PİRİNÇ BANT EKSPANLI ESNEK PRİMER PİST AYDINLATMA KABLOSU – TİP B**  
*FLEXIBLE PRIMARY AIRPORT LIGHTING CABLE WITH BRASS TAPE SCREEN – TYPE B*

**ICEA S-93-639 / NEMA WC74**

*FAA – L 824 ( AC - 150/5375-7E SPECIFICATION FOR L-824)*

### KABLO YAPISI

- \* İLETKEN : Tavlı Bakır İletken (Tip TBC ) veya Kalaylı (Tip BBC ) Bakır İletken - IEC C 60228 CL 2' ye göre
- \* YARI İLETKEN TABAKA : Ekstruze yarı iletken tabaka - ICEA S-93-639 / NEMA WC74' e göre
- \* İZOLE : EPR Kauçuk - ICEA S-93-639 / NEMA WC74' e göre
- \* YARI İLETKEN TABAKA : Yarı iletken bant - ICEA S-93-639 / NEMA WC74' e göre
- \* EKSPAN : Minimum %20 bindirmeli ve %100 kapamalı olarak helisel uygulanmış pirinç bant
- \* DIŞ KILIF : PCP veya eşdeğeri malzeme - ICEA S-93-639 / NEMA WC74' e göre

### CABLE STRUCTURE

- \* CONDUCTOR : Strand of annealed tinned copper wires (Type TBC ) or plain copper wires (Type BBC ) according to IEC C 60228 CL 2
- \* SEMICONDUCTIVE LAYER : Extruded Semiconductive material according to ICEA S-93-639 / NEMA WC74
- \* INSULATION : EPR Rubber according to ICEA S-93-639 / NEMA WC74
- \* SEMICONDUCTIVE LAYER : Semiconductive tape according to ICEA S-93-639 / NEMA WC74
- \* SCREEN : Minimum 20% overlap and 100% coverage ratio helically applied Brass Tape
- \* OUTER JACKET : PCP or equivalent material according to ICEA S-93-639 / NEMA WC74



### ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARTI / STANDARD OF TEST : ICEA S-93-639 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
*All sizes are available in AWG and Metric*